

# NOTICE ABOUT YOUR DRINKING WATER

## Failure to Correct a Significant Deficiency

Public Water System Name: Emerald Lake Village District PWS ID: 1141020

We are required to correct significant water system deficiencies identified by Department of Environmental Services (NHDES). We failed to take the required action by the established date.

**This is not an emergency.** If it had been, you would have been notified immediately. We do not know of any case of contamination. However, until the problem is corrected, there is an increased chance that disease causing organisms could contaminate the water supply and potentially cause an illness.

*Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms include bacteria, viruses and parasites which can cause symptoms such as; nausea, cramps, diarrhea and associated headaches. These symptoms, however, are not caused only by organisms in drinking water, but also by other factors. If you experience any of these symptoms and they persist, you may want to seek medical advice.*

**What should I do?** There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions.

The table below lists the outstanding significant deficiency(ies), when correction of the deficiency(ies) was due and the corrective action we have (or will be) taking.

Significant Deficiency(ies) Noted	Date(s) Correction was Due
Source Capacity Issues	February 22, 2019

Steps being taken to correct the situation:

Continue to apply for yearly leak detection grant and perform additional leak detection as necessary, presented and was approved by residents at the 2024 Annual Meeting for the next phase of water main replacement project, presented and approved by residents at the 2024 Annual Meeting for a "toilet flapper project" Source Water protection grant, monitor zone meter readings for any spikes in usage. Expected Resolution Date: December 2026

Contact Name: Sara Auger Company: Emerald Lake Village District

Address: 147 W. Main St, Hillsboro NH 03244 Telephone Number: 603-464-3128

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example; people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.**